

***FRAZIER PARK PUBLIC UTILITY  
DISTRICT***

**MANAGERS REPORT**

**For the month of December 2020**

**Prepared by:**

**Jonnie Allison, General Manager**

**Frazier Park Public Utility District**

## INFORMATIONAL ITEMS

### I. WATER REPORT

**Water Pumped this month 916,300 Cubic Ft.**

**Water sold: 639,670 Cubic Ft.**

**Water used for Fire & Flushing Line: 64,141 Cubic Ft.**

**Lag Differential: 23.19%**

**Water Loss: 212,489 Cubic Feet**

**Average chlorine residual: 0.70 MG/L**

### II. MAINTENANCE AND REPAIR: December 2020

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	2	3	21
AFTER HOUR CALL OUTS	14	12	102
MAIN LINE LEAK REPAIRS	4	2	37
USA LOCATES	9	10	404
SERVICE/WORK ORDERS	209	217	2839
CUSTOMER "TURN-ONS"	3	2	24
CUSTOMER "TURN-OFFS"	1	4	22
LOCK OFF (NON PAYMENT)	0	0	17
SERVICE RECONNECT	2	0	22
SHUT OFF NOTICES	0	0	62
GALLONS CL2 USED	145	154	1641
WATER QUALITY COMPLAINTS	0	0	0

### III. WATER QUALITY COMPLAINTS:

#### **IV. ISSUES AND ACTIONS:**

There was (4) mainline break(s) / repair(s) in the month of December 2020

Location	Dates	Comments
4109 Locust/Elm	12/03/20	8" Steel
4236 Logan/Grant	12/07/20	2" Steel
North End/Summit	12/14/20	6" Steel
Los Padres/Escolon Trail	12/16/20	2" Steel

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
  
- There were (14) after hour callout(s) in the month of December 2020

Location	Dates	Comments
Well 6	12/02/20	System Alarm/Pump Failure Reset Cabinet
721 Alhambra	12/04/20	Frozen Pipes
Sam Young Tank	12/06/20	PLC Communication Issue
Harrison Booster/Tank	12/06/20	PLC Communication Issue
Harrison	12/06/20	PLC Communication Issue
Harrison	12/06/20	PLC Communication Issue Shut off boosters until 12/07/20
4008 Roosevelt	12/25/20	Emergency Shut Off/Broken Pipes
Well 6	12/26/20	Chlorinator Failure
Well 6	12/26/20	Verifying that Chlorine Residual is rising after repair
Well 5 Booster 1	12/26/20	Booster pump failed/Reset
4225 Alcot	12/31/20	Answering Service Reported Water Leak. No leak found
Office Alarm	12/31/20	M&S reported Office Alarm. Nothing Discovered. Reset Alarm
Well 5 Booster 1	12/31/20	Booster Pump Failed/Reset
Well 5 Booster 1	12/31/20	Booster Pump Failed/Turned off until 1/1/21

**V. NEW SERVICES INSTALLED: (0)**

Address		Lot / Block / Tract	Size

**VI. NEW BUSINESS:**

■ **APPLICATIONS FOR WATER SERVICE - 0**