FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGERS REPORT

For the month of May 2020

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,052,300 Cubic Ft.

Water sold: 798,387 Cubic Ft.

Water used for Fire & Flushing Line: 73,661 Cubic Ft.

Lag Differential: 17.13%

Water Loss: 180,252 Cubic Feet

Average chlorine residual: 0.70 MG/L

II. MAINTENANCE AND REPAIR: May 2020

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	1	3
AFTER HOUR CALL OUTS	17	3	34
MAIN LINE LEAK REPAIRS	4	6	15
USA LOCATES	12	3	30
SERVICE/WORK ORDERS	331	357	1194
CUSTOMER "TURN-ONS"	0	3	8
CUSTOMER "TURN-OFFS"	0	3	10
LOCK OFF (NON PAYMENT)	0	0	16
SERVICE RECONNECT	0	0	19
SHUT OFF NOTICES	0	0	62
GALLONS CL2 USED	152	138	727
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. <u>ISSUES AND ACTIONS:</u>

There was (4) mainline break(s) / repair(s) in the month of May 2020

Location	Dates	Comments
4236 Grant/Logan	05/05/20	2" Steel
339 Oregon/Manita	05/05/20	6" Steel
Hale/Ash Trail	05/11/20	2" Steel (2" x 3" Compression Clamp)
Hale/Ash Trail	05/12/20	6" Steel (6" x 7 ½" Repair Clamp)

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (17) after hour callout(s) in the month of May 2020

Location	Dates	Comments
4236 Grant Trail	05/15/20	Leak on 2" Mainline
4128 Mt. Pinos	05/30/20	Mainline Leak
Wolfe Tank Booster	05/31/20	2" Steel Pipe Broke and flooded down the hillside
The other 14 Callout	Are related	To running the booster at wolfe by hand.

V. <u>NEW SERVICES INSTALLED:</u> (0)

Address	Lot / Block / Tract	Size

VI. NEW BUSINESS:

■ APPLICATIONS FOR WATER SERVICE - 0