FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGERS REPORT

For the month of June 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,481,100 Cubic Ft.

Water sold: 1,192,900 Cubic Ft.

Water used for Fire & Flushing Line: 103,677 Cubic Ft.

Lag Differential: 12.46%

Average chlorine residual: 0.55 MG/L

II. MAINTENANCE AND REPAIR: June 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	1	6
AFTER HOUR CALL OUTS	3	4	26
MAIN LINE LEAK REPAIRS	1	2	24
USA LOCATES	22	34	134
SERVICE/WORK ORDERS	151	157	910
CUSTOMER "TURN-ONS"	3	3	22
CUSTOMER "TURN-OFFS"	4	2	17
LOCK OFF (NON PAYMENT)	11	4	53
SERVICE RECONNECT	7	4	31
SHUT OFF NOTICES	47	51	290
GALLONS CL2 USED	91	95	547
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (1) mainline break(s) / repair(s) in the month of June 2017

Location	Dates	Comments
Los Padres & Laguna	6/29/17	6" Mainline Leak

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (3) after hour callout(s) in the month of June 2017

Location	Dates	Comments
Elm Trail	6/09/17	Valve Can Lid Open.
3732 North End	6/17/17	Leak Reported. No Leak.
Mt. Pinos & Canada	6/30/17	Leak Reported. Sprinkler Leak

V. <u>NEW SERVICES INSTALLED:</u> (O)

Address	Lot / Block / Tract	Size

VI. NEW BUSINESS:

■ APPLICATIONS FOR WATER SERVICE -