

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of October 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,108,200 Cubic Ft.

Water sold: 916,800 Cubic Ft.

Water used for Fire & Flushing Line: 77,574 Cubic Ft.

Lag Differential: 10.27%

Average chlorine residual: 0.53 MG/L

II. MAINTENANCE AND REPAIR: October 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	4	1	17
AFTER HOUR CALL OUTS	2	1	32
MAIN LINE LEAK REPAIRS	1	0	30
USA LOCATES	12	14	192
SERVICE/WORK ORDERS	185	140	1546
CUSTOMER "TURN-ONS"	3	1	27
CUSTOMER "TURN-OFFS"	2	2	25
LOCK OFF (NON PAYMENT)	16	4	93
SERVICE RECONNECT	12	11	65
SHUT OFF NOTICES	50	44	443
GALLONS CL2 USED	92	98	834
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (1) mainline break(s) / repair(s) in the month of October 2017

Location	Dates	Comments
Manita & Oregon	10/06/17	3" Mainline Break

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (2) after hour callout(s) in the month of October 2017

Location	Dates	Comments
Manita & Oregon	10/06/17	3" Mainline Break
Pico Trail	10/07/17	Pressure Regulator Failed (Customer Side)

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE –**