

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of November 2019

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,192,800 Cubic Ft. approx.

Water sold: 931,380 Cubic Ft.

Water used for Fire & Flushing Line: 83,496 Cubic Ft.

Lag Differential: 14.92%

Average chlorine residual: 0.62 MG/L

II. MAINTENANCE AND REPAIR: November 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	2	9
AFTER HOUR CALL OUTS	5	0	48
MAIN LINE LEAK REPAIRS	0	1	24
USA LOCATES	6	8	129
SERVICE/WORK ORDERS	145	161	1915
CUSTOMER "TURN-ONS"	1	1	21
CUSTOMER "TURN-OFFS"	1	1	18
LOCK OFF (NON PAYMENT)	5	8	62
SERVICE RECONNECT	4	6	59
SHUT OFF NOTICES	37	29	351
GALLONS CL2 USED	148	160	1506
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (0) mainline break(s) / repair(s) in the month of November 2019

Location	Dates	Comments

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (5) after hour callout(s) in the month of November 2019

Location	Dates	Comments
Auto Dialer	11/27/19	System Alarm.
Johnson Road	11/27/19	Leak at House. Repaired when we got there.
District Yard	11/28/19	Alarm due to fog.
East End	11/28/19	Emergency Shutoff
Main Trail	11/29/19	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**

