# FRAZIER PARK PUBLIC UTILITY DISTRICT

# **MANAGERS REPORT**

For the month of May 2021

# Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

#### **INFORMATIONAL ITEMS**

#### I. WATER REPORT

Water Pumped this month 1,139,200 Cubic Ft.

Water sold: 717,140 Cubic Ft.

Water used for Fire & Flushing Line: 79,744 Cubic Ft.

Lag Differential: 30.05%

Water Loss: 342,316 Cubic Feet

Average chlorine residual: 0.74 MG/L

## II. MAINTENANCE AND REPAIR: May 2021

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	3	0	8
AFTER HOUR CALL OUTS	10	5	59
MAIN LINE LEAK REPAIRS	2	1	11
USA LOCATES	2	15	88
SERVICE/WORK ORDERS	183	150	765
CUSTOMER "TURN-ONS"	0	0	2
CUSTOMER "TURN-OFFS"	0	1	6
LOCK OFF (NON PAYMENT)	0	0	0
SERVICE RECONNECT	1	0	1
SHUT OFF NOTICES	0	0	0
GALLONS CL2 USED	149	175	745
WATER QUALITY COMPLAINTS	0	0	0

#### **III.** WATER QUALITY COMPLAINTS:

#### IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of May 2021

Location	Dates	Comments
721 San Miguel & Mt.	5/5/21	4" Steel
Pinos		Used Two Clamps
North End & Oregon Trail	5/12/21	4" Steel
		Used One Clamp

Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

There were (10) after hour callout(s) in the month of May 2021

There were (10) after from canout(s) in the month of may 2021					
Location	Dates	Comments			
Parcel B System Alarm	5/5/21	Communication Failure			
4345 Decator	5/7/21	Customer Hose Running			
305 Pine Canyon	5/15/21	Emergency Shutoff			
909 Piedmont	5/15/21	Emergency Shutoff			
Corporate Yard	5/19/21	Yard Alarm. Responded and found nothing. Reset Alarm			
Sam Young & Harrison	5/21/21	Communication Failures			
Parcel B	5/21/21	PLC Alarm			
637 Santa Cruz	5/22/21	Customer reported No Water Determined it was on customers side			
Elm Tank	5/23/21	Communication Failure			
Sam Young Tank	5/23/21	PLC Alarm			

# V. <u>NEW SERVICES INSTALLED:</u> (0)

Address	Lot / Block / Tract	Size

### VI. <u>NEW BUSINESS:</u>

■ APPLICATIONS FOR WATER SERVICE – 0