

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of November 2018

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,141,300 Cubic Ft.

Water sold: 909,668 Cubic Ft. After Correction

Water used for Fire & Flushing Line: 79,891 Cubic Ft.

Lag Differential: %

Average chlorine residual: 1.01 MG/L

II. MAINTENANCE AND REPAIR: November 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	6	6	17
AFTER HOUR CALL OUTS	0	2	23
MAIN LINE LEAK REPAIRS	1	4	19
USA LOCATES	14	13	128
SERVICE/WORK ORDERS	195	188	1756
CUSTOMER "TURN-ONS"	0	2	11
CUSTOMER "TURN-OFFS"	0	2	14
LOCK OFF (NON PAYMENT)	4	11	91
SERVICE RECONNECT	9	6	72
SHUT OFF NOTICES	23	35	323
GALLONS CL2 USED	139	157	1266
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (1) mainline break(s) / repair(s) in the month of November 2018

Location	Dates	Comments
Texas Trail & East End	11/17/18	4" Mainline Leak

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (0) after hour callout(s) in the month of November 2018

Location	Dates	Comments

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**