

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of April 2019

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 900,000 Cubic Ft.

Water sold: 679,536 Cubic Ft.

Water used for Fire & Flushing Line: 63,000 Cubic Ft.

Lag Differential: 17.50%

Average chlorine residual: 1.04 MG/L

II. MAINTENANCE AND REPAIR: April 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	0	2
AFTER HOUR CALL OUTS	1	4	21
MAIN LINE LEAK REPAIRS	2	2	9
USA LOCATES	29	4	51
SERVICE/WORK ORDERS	214	209	700
CUSTOMER "TURN-ONS"	2	2	9
CUSTOMER "TURN-OFFS"	1	2	6
LOCK OFF (NON PAYMENT)	8	4	21
SERVICE RECONNECT	7	3	20
SHUT OFF NOTICES	42	30	152
GALLONS CL2 USED	120	112	476
WATER QUALITY COMPLAINTS	0	0	

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of April 2019

Location	Dates	Comments
Los Padres & Santa Cruz	4/3/19	4" Mainline
3203 Mt. Pinos	4/22/19	4" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (1) after hour callout(s) in the month of April 2019

Location	Dates	Comments
M & S Alarm	4/24/19	District Yard Alarm

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 1**