

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of March 2021

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 857,900 Cubic Ft.

Water sold: 564,310 Cubic Ft.

Water used for Fire & Flushing Line: 60,053 Cubic Ft.

Lag Differential: 27.22%

Water Loss: 233,537 Cubic Feet

Average chlorine residual: 0.79 MG/L

II. MAINTENANCE AND REPAIR: March 2021

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	3	0	5
AFTER HOUR CALL OUTS	5	26	44
MAIN LINE LEAK REPAIRS	2	1	8
USA LOCATES	63	8	71
SERVICE/WORK ORDERS	186	243	432
CUSTOMER "TURN-ONS"	1	0	2
CUSTOMER "TURN-OFFS"	1	2	5
LOCK OFF (NON PAYMENT)	0	0	0
SERVICE RECONNECT	0	0	0
SHUT OFF NOTICES	0	0	0
GALLONS CL2 USED	148	130	421
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of March 2021

Location	Dates	Comments
4405 Hale/Mead	3/01/21	5.95-6.35 X 12.5 Clamp
4128 Mt. Pinos	3/25/21	2.38 Clamp

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (5) after hour callout(s) in the month of March 2021

Location	Dates	Comments
4128 Mt. Pinos	3/19/21	2" Mainline Leak
Pine 1	3/21/21	PLC Alarm
Forestry	3/21/21	PLC Alarm
Forestry	3/25/21	PLC Alarm
Corporate Yard	3/28/21	Yard Alarm

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 1**
3428 Dakota Trail. Not investigated yet

- 1.) 3501 Nebraska Trail. **Paid in full**
- 2.) Lot-block-track 13-15-4 High Trail and West End. **Paid in Full**
- 3.) 3525 Illinois-\$200 deposit forfeited. Application Date 9/10/21