

FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGER'S REPORT

For the month of August 2026

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,625,300 Cubic Ft.

Water sold: 1,005,000 Cubic Ft.

Water used for Fire & Flushing Line: 113,771 Cubic Ft.

Water Loss: 506,529 Cubic Ft.

Lag Differential: 31.17%

II. MAINTENANCE AND REPAIR: August 2026

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	0	1
AFTER HOUR CALL OUTS	0	1	13
MAIN LINE LEAK REPAIRS	1	3	16
USA LOCATES	12	12	122
SERVICE/WORK ORDERS***	251	176	2455
CUSTOMER "TURN-ONS"	0	2	8
CUSTOMER "TURN-OFFS"	0	3	12
LOCK OFF (NON PAYMENT)	6	4	63
SERVICE RECONNECT	6	3	59
SHUT OFF NOTICES	39	31	313
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	1	0	2
SERVICE LINE BREAKS	0	0	0
BOIL WATER NOTICES	40	0	740

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (1) mainline break(s) / repair(s) in the month of August 2026

Location	Dates	Comments
North End above Manita 3970	8/26/26	3 leaks, all three were fixed with 5.95-6.35 clamps

- There was (0) after hour callout(s) in the month of August 2026

Location	Date	Reason

V. NEW SERVICES INSTALLED: (1)

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE – 1**