FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGER'S REPORT

For the month of October 2026

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,389,600 Cubic Ft.

Water sold: 818,200 Cubic Ft.

Water used for Fire & Flushing Line: 97,272 Cubic Ft.

Water Loss: 474,128 Cubic Ft.
Lag Differential: 34.12%

II. MAINTENANCE AND REPAIR: October 2026

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	1	2
AFTER HOUR CALL OUTS	0	0	13
MAIN LINE LEAK REPAIRS	3	4	23
USA LOCATES	10	13	145
SERVICE/WORK ORDERS***	898	246	3797
CUSTOMER "TURN-ONS"	0	2	10
CUSTOMER "TURN-OFFS"	2	2	16
LOCK OFF (NON PAYMENT)	5	18	86
SERVICE RECONNECT	6	12	77
SHUT OFF NOTICES	36	56	405
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	0	1	2
SERVICE LINE BREAKS	0	0	0
BOIL WATER NOTICES	700	0	1440

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (3) mainline break(s) / repair(s) in the month of October 2026

Location	Dates	Comments
3620 Los Padres Dr. and Alahambra Trail	10/1/26	Pipe navigated from North to South towards Alahambra Trail. Clamp used was 3.96-4.25. The pipe was located Aprox. 6' feet down.
824 Ave I/Escolon	10/14/26	Pipe appears to be degrading. Estimated 0/0 was 1.40". Pipe was about 2' feet down. IPS/Poly could be crimped to slow or shut water down.
803 Los Padres and San Miguel	10/28/26	Pipe was Aprox. 4' down underneath the North side of the street running parallel with Los Padres. 8' section was replaced with C900 due to multiple clamps already on the pipe.

■ There was (0) after hour callout(s) in the month of October 2026

Location	Date	Reason

V. NEW SERVICES INSTALLED: (0)

VI. NEW BUSINESS:

■ **APPLICATIONS FOR WATER SERVICE – 0**