FRAZIER PARK PUBLIC UTILITY DISTRICT

MANAGERS REPORT

For the month of February 2017

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 863,700 Cubic Ft

Water sold: 676,100 Cu Ft Lag Differential: 14.72 %

Average chlorine residual: 0.71 MG/L

II. MAINTENANCE AND REPAIR: February 2017

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	3	0
AFTER HOUR CALL OUTS	6	7	13
MAIN LINE LEAK REPAIRS	8	4	12
USA LOCATES	7	20	27
SERVICE/WORK ORDERS	136	124	260
CUSTOMER "TURN-ONS"	2	4	6
CUSTOMER "TURN-OFFS"	1	2	3
LOCK OFF (NON PAYMENT)	8	8	16
SERVICE RECONNECT	2	5	7
SHUT OFF NOTICES	49	37	86
GALLONS CL2 USED	85	95	180
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (8) mainline break(s) / repair(s) in the month of February 2017

Location	Dates	Comments
East End	2/03/17	2" Mainline Repair
East End	2/03/17	6" Mainline Repair
Nebraska	2/07/17	Cap & Remove 20' Leaking Old Line
Creek Bed	2/17/17	8" Transmission Line Torn Out in Flood
Pine Canyon	2/18/17	8" Pipe Failure
Forestry Tank Creek	2/18/17	8" Transmission Line-5 Repair Clamps Needed
Manita	2/22/17	3 ½" Mainline Leak
Pine 1 Tank	2/23/17	8" Mainline Repair

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (6) after hour callout(s) in the month of February 2017

Location	Dates	Comments
East End	2/03/17	2" Mainline Repair
Iron & Mead	2/04/17	Service Line Leak
System Alarm	2/12/17	Well 6
Creek	2/17/17	Transmission Line Temporary Repair
Pine Canyon	2/18/17	Facilitate Repairs with Santana on 8" Mainline
District	2/19/17	Pass out Boil Notices

V. NEW SERVICES INSTALLED: (0)

Address	Lot / Block / Tract	Size

VI. <u>NEW BUSINESS:</u>

■ APPLICATIONS FOR WATER SERVICE -