

***FRAZIER PARK PUBLIC UTILITY  
DISTRICT***

**MANAGERS REPORT**

**For the month of January 2018**

**Prepared by:**

**Jonnie Allison, General Manager**

**Frazier Park Public Utility District**

## INFORMATIONAL ITEMS

### I. WATER REPORT

**Water Pumped this month 1,015,300 Cubic Ft.**

**Water sold: 752,100 Cubic Ft.**

**Water used for Fire & Flushing Line: 71,071 Cubic Ft.**

**Lag Differential: 18.92%**

**Average chlorine residual: 0.77 MG/L**

### II. MAINTENANCE AND REPAIR: January 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	1	0	1
AFTER HOUR CALL OUTS	1	1	1
MAIN LINE LEAK REPAIRS	1	1	1
USA LOCATES	13	9	13
SERVICE/WORK ORDERS	172	140	172
CUSTOMER "TURN-ONS"	0	0	0
CUSTOMER "TURN-OFFS"	0	1	0
LOCK OFF (NON PAYMENT)	7	9	7
SERVICE RECONNECT	5	9	5
SHUT OFF NOTICES	32	31	32
GALLONS CL2 USED	90	94	90
WATER QUALITY COMPLAINTS	0	0	0

### III. WATER QUALITY COMPLAINTS:

**IV. ISSUES AND ACTIONS:**

There was (1) mainline break(s) / repair(s) in the month of January 2018

Location	Dates	Comments
East End	1-14-18	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (1) after hour callout(s) in the month of January 2018

Location	Dates	Comments
East End	1-14-18	Mainline Rupture

**V. NEW SERVICES INSTALLED: (0)**

Address		Lot / Block / Tract	Size

**VI. NEW BUSINESS:**

- **APPLICATIONS FOR WATER SERVICE -**