

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of August 2024

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,480,000 Cubic Ft.

Water sold: 958,540 Cubic Ft.

Water used for Fire & Flushing Line: 103,600 Cubic Ft.

Water Loss: 417,860 Cubic Ft.

Lag Differential: 28.23%

II. MAINTENANCE AND REPAIR: August 2024

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	9	41
AFTER HOUR CALL OUTS	3	3	39
MAIN LINE LEAK REPAIRS	1	3	26
USA LOCATES	7	11	116
SERVICE/WORK ORDERS***	252	231	1299
CUSTOMER "TURN-ONS"	1	2	11
CUSTOMER "TURN-OFFS"	0	5	23
LOCK OFF (NON PAYMENT)	11	13	70
SERVICE RECONNECT	11	16	74
SHUT OFF NOTICES	12	13	338
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	0	0	0
SERVICE LINE BREAKS	0	0	0
BOIL WATER NOTICES	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (1) mainline break(s) / repair(s) in the month of August 2024

Location	Dates	Comments
Catalina/Mt Pinos	8.30.24	1"Steel 1- 1.32x 3-2 Bolt/Clamp

- There was (3) after hour callout(s) in the month of August 2024
Reason:

Location:	Date:	Reason
Corner of Decator/Julin	8.14.24	Replaced Valve Can Lid
Panel Room	8.8.24	Alarm
4204 Poplar Tr	8.25.24	Tightened Meter Coupling On Customer Side

V. NEW SERVICES INSTALLED: (0)

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**