

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of October 2018

Prepared by:

**Jonnie Allison, General Manager
Frazier Park Public Utility District**

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,057,400 Cubic Ft.

Water sold: 786,900 Cubic Ft.

Water used for Fire & Flushing Line: 74,018 Cubic Ft.

Lag Differential: 18.58%

Average chlorine residual: 0.71 MG/L

II. MAINTENANCE AND REPAIR: October 2018

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	6	0	11
AFTER HOUR CALL OUTS	2	1	23
MAIN LINE LEAK REPAIRS	4	4	18
USA LOCATES	13	6	114
SERVICE/WORK ORDERS	188	160	1561
CUSTOMER "TURN-ONS"	2	1	11
CUSTOMER "TURN-OFFS"	2	2	14
LOCK OFF (NON PAYMENT)	11	4	87
SERVICE RECONNECT	6	6	63
SHUT OFF NOTICES	35	25	300
GALLONS CL2 USED	157	154	1127
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (4) mainline break(s) / repair(s) in the month of October 2018

Location	Dates	Comments
Elm Trail & Poplar	10/01/18	8" Mainline
Los Padres	10/04/18	2" Mainline
2816 Johnson	10/29/18	4" Mainline
3912 Michigan	10/31/18	2" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (2) after hour callout(s) in the month of October 2018

Location	Dates	Comments
2908 Harriot	10/13/18	Emergency Shutoff/Curb stop Repair
933 Hemingway	10/16/18	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE -**