

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of May 2019

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,137,000 Cubic Ft.

Water sold: 942,423 Cubic Ft.

Water used for Fire & Flushing Line: 79,590 Cubic Ft.

Lag Differential: 10.11%

Average chlorine residual: 0.88 MG/L

II. MAINTENANCE AND REPAIR: May 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	1	2
AFTER HOUR CALL OUTS	1	1	22
MAIN LINE LEAK REPAIRS	2	2	11
USA LOCATES	15	29	66
SERVICE/WORK ORDERS	186	214	886
CUSTOMER "TURN-ONS"	1	2	10
CUSTOMER "TURN-OFFS"	3	1	9
LOCK OFF (NON PAYMENT)	6	8	27
SERVICE RECONNECT	3	7	23
SHUT OFF NOTICES	27	42	179
GALLONS CL2 USED	124	120	600
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of May 2019

Location	Dates	Comments
4085 Pico	5/11/19	4" Mainline
Carnelia & Montana	5/13/19	1" Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (1) after hour callout(s) in the month of May 2019

Location	Dates	Comments
2825 Johnson	5/11/19	Emergency Shutoff

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**