

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of July 2019

Prepared by:

**Jonnie Allison, General Manager
Frazier Park Public Utility District**

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 1,058,400 Cubic Ft.

Water sold: 1,083,840 Cubic Ft.

Water used for Fire & Flushing Line: 87,311 Cubic Ft.

Lag Differential: -9.40%

Average chlorine residual: 0.67 MG/L

II. MAINTENANCE AND REPAIR: July 2019

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	1	3
AFTER HOUR CALL OUTS	12	9	43
MAIN LINE LEAK REPAIRS	2	3	16
USA LOCATES	16	10	92
SERVICE/WORK ORDERS	193	185	1264
CUSTOMER "TURN-ONS"	4	1	15
CUSTOMER "TURN-OFFS"	1	1	11
LOCK OFF (NON PAYMENT)	7	3	37
SERVICE RECONNECT	7	6	36
SHUT OFF NOTICES	26	24	229
GALLONS CL2 USED	155	120	875
WATER QUALITY COMPLAINTS	0	0	0

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of July 2019

Location	Dates	Comments
Manita & Pico	7/2/19	4" Mainline
4020 Park Drive	7/8/19	¾ Mainline

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.
- There were (12) after hour callout(s) in the month of July 2019

Location	Dates	Comments
Auto Dialer	7/2/19	Scada/Telemetry
Auto Dialer	7/4/19	Scada/Telemetry
Auto Dialer	7/6/19	Scada/Telemetry
System Alarm	7/11/19	Elm Level & Booster Alarm
Well 5	7/12/19	Turn on Well 5
Well 5	7/12/19	Turn Off Well 5
Wolfe Tank	7/13/19	PLC Issues
Well 5	7/13/19	Turn on Well 5
Well 5	7/14/19	High Float Well 5
Sam Young & Harrison	7/14/19	PLC Issues at both Sites
Kern County Park	7/17/19	Leak by War Memorial
Auto Dialer	7/20/19	Scada/Telemetry

V. NEW SERVICES INSTALLED: (0)

Address		Lot / Block / Tract	Size

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**