

***FRAZIER PARK PUBLIC UTILITY  
DISTRICT***

**MANAGERS REPORT**

**For the month of January 2021**

**Prepared by:**

**Jonnie Allison, General Manager**

**Frazier Park Public Utility District**

## INFORMATIONAL ITEMS

### I. WATER REPORT

**Water Pumped this month 930,100 Cubic Ft.**

**Water sold: 655,210 Cubic Ft.**

**Water used for Fire & Flushing Line: 65,107 Cubic Ft.**

**Lag Differential: 22.56%**

**Water Loss: 209,783 Cubic Feet**

**Average chlorine residual: 0.82 MG/L**

### II. MAINTENANCE AND REPAIR: January 2021

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	2	0
AFTER HOUR CALL OUTS	13	14	13
MAIN LINE LEAK REPAIRS	5	4	5
USA LOCATES	0	9	0
SERVICE/WORK ORDERS	203	217	203
CUSTOMER "TURN-ONS"	1	3	1
CUSTOMER "TURN-OFFS"	2	1	2
LOCK OFF (NON PAYMENT)	0	0	0
SERVICE RECONNECT	0	2	0
SHUT OFF NOTICES	0	0	0
GALLONS CL2 USED	143	145	143
WATER QUALITY COMPLAINTS	0	0	0

### III. WATER QUALITY COMPLAINTS:

#### **IV. ISSUES AND ACTIONS:**

There was (5) mainline break(s) / repair(s) in the month of January 2021

Location	Dates	Comments
4128 Mt. Pinos	1/05/21	2" Steel 2.38 Single Bolt Clamp
3621 Los Padres	1/06/21	2" Steel 2.38" Single Bolt Clamp
Wolfe Tank Hillside	1/07/21	6" Steel 6.56-6.84 x 7.5 Clamp
Elm & Mt. Pinos (South Side)	1/17/21	8" Steel 7.95-8.35 x 7.5
3609 Los Padres	1/19/21	2" Steel (2) 2.38 Single Bolt Clamps

- Nine (9) routine bacteriological samples were completed in compliance with the California Department of Public Health water quality regulations: Four (4) samples within the distribution system, and five (5) more at our wells and springs. Both Sam Young & Pine Canyon Springs are isolated from the system.

- There were (13) after hour callout(s) in the month of January 2021

Location	Dates	Comments
Frazier Park	1/01/21	Emergency Shutoff (Frozen Pipes)
Well 5	1/02/21	Booster Pump 1 Failure Alarm
3906 Park Drive	1/03/21	Emergency Shutoff (Frozen Pipe)
Well 5	1/03/21	Booster Pump 1 Failure Alarm
Elm & Mt. Pinos	1/17/21	8" Steel
Wolfe Booster	1/18/21	Communication Failure
Sam Young	1/18/21	Communication Failure
3205 Mt. Pinos	1/22/21	Emergency Shutoff (Frozen Pipe)
Elm Tank	1/23/21	Elm Booster 1 Failure Alarm
Elm Tank	1/24/21	Elm Booster 1 Failure Alarm
Corporate Yard	1/25/21	M & S Alarm
Elm Tank	1/28/21	Elm Booster 1 Failure Alarm
Well 5	1/29/21	Booster Pump 1 Failure Alarm

**V. NEW SERVICES INSTALLED: (0)**

Address		Lot / Block / Tract	Size

**VI. NEW BUSINESS:**

- APPLICATIONS FOR WATER SERVICE – 0**